



nelson mandela bay
M U N I C I P A L I T Y
PORT ELIZABETH | UITENHAGE | DESPATCH

INFRASTRUCTURE & ENGINEERING

Tel: +27(41) 506 2911, fax: +27(41) 506 2180
PO Box 7, Port Elizabeth 6000
Republic of South Africa
e-mail: JTSATSIR@mandelametro.gov.za

Your Ref:
Our Ref: 203/01/01/19; 203/16/03
Letter ID:

DEALS WITH THIS MATTER: **MR J. TSATSIRE/AB**
Tel: **(041) 506-2101**; Fax: **(041) 506-2180**
Date: **4 February 2008**

Engineering Advice and Services
P O Box 13867
Humewood
PORT ELIZABETH
6013

Dear Sirs

PARSONSVLEI – ERF 2661 : BULK WATER AUGUMENTATION : DESIGN DRAWINGS FOR 500mm DIAMETER PIPELINE FROM CHELSEA RESERVOIR TO CAPE ROAD : CH620m – CH2448m

Your letter dated 8 November 2007, refers.

The bulk water reticulation layout indicated on your attached drawing numbers 426-FIG-01, 426-FIG-02A, 426-FIG-03, 426-FIG-04, 426-FIG-05, 426-FIG-06 and 426-FIG-07 have been satisfactorily amended and are hereby approved.

The following procedure will be followed in testing and connecting of the bulk water main into municipal reticulation:

- The contractor will perform a hydraulic water test on the newly built water main
- Municipal officials will witness a successful hydraulic water test
- Your contractor will connect into municipal water mains.
- Municipal officials will isolate and supervise the connection work being undertaken by your contractor

The cost of supervision and isolation of municipal water reticulation at corner Cape Road and Seaview Road and at the start of CH 620 will be R 2 500 and R 5 000 respectively.

Yours faithfully

A A SAID Pr. Eng.
EXECUTIVE DIRECTOR :
INFRASTRUCTURE & ENGINEERING

Enclosures